



Commercial Rebates

ECM FAN MOTOR RETROFITS

All projects shall comply with the General Qualifications/Guidelines to qualify for a rebate. Please refer to the General Qualifications/Guidelines document for further details.

SPECIFIC QUALIFICATIONS

1. No Pre-inspection will be required IF removed fan motors are left on site for final inspection.
2. The removed fan motors must not be re-used within the City of Austin’s utility system and must remain on-site for final verification purposes and disposed of after inspection unless previous arrangements have been made with Austin Energy.
3. Fan controllers cannot be used in conjunction with new fan motors.
4. The replacement motor must be an ECM (electronically commutated motor) type.
5. New construction projects are not eligible for fan motor retrofit payments.

Table 1 – Fan Motor Rebate Table				
			Existing Fan Motor	
Horsepower	Horsepower	Wattage	SP*	PSC**
1/120	0.008	6	\$4	N/A
1/82	0.0125	9	\$6	N/A
1/30	0.033	25	\$16	\$6
1/20	0.050	37	\$25	\$10
1/12	0.083	62	\$42	\$16
1/10	0.100	75	\$50	\$20
1/8	0.125	93	\$63	\$24
1/6	0.167	124	\$84	\$32

*Shaded Pole **Permanent Split Capacitor

Austin Energy – Power Saver Program – Commercial Rebate

811 Barton Springs Road, 3rd Floor Austin, TX 78704 Phone (512) 482-5346 FAX (512) 505-4026

Email: conservation@austinenergy.com website: <http://www.austinenergy.com/go/commercialrebates>